



789 N. Dixboro Rd. Ann Arbor, MI 48105, USA
1-800.NSF.MARK | +1-734.769.8010 | www.nsf.org

EVALUATION REPORT

Send To: C0609840

Mr. Eduardo Diaz
Nature Works Technologies S.L.
C/Tabarca, 16
Alfas del Pi
03580 Alicante
Spain


Facility: C0609841

Grupo Camacho Logistic Center
P.I. Tecnológico
Caudete ES-AB 02660
Spain

Result	PASS	Report Date	23-FEB-2024
Customer Name	Nature Works Technologies S.L.		
Tested To	NSF/ANSI/CAN 61		
Description	Nature Works Tecnologías S.L. Solid		
Trade Designation	Nature Works Tecnologías S.L.		
Test Type	Qualification Retest		
Job Number	J-00435855		
Project Number	W0766283		
Project Manager	Javier Marin Jimenez		

Thank you for having your product tested by NSF.

Please contact your Project Manager if you have any questions or concerns pertaining to this report.

Report Authorization 
Scott E. Randall - Senior Manager Commercial Water

Date 23-FEB-2024



General Information

Standard: NSF/ANSI/CAN 61

Lot Number: NW-STAGE1-23/05/11-0021

Physical Description of Sample: Solid

Tested DCC Number: IA34309

Trade Designation/Model Number: Nature Works Tecnologías S.L.

Sample Id: **S-0002085626**
 Description: Sample exposed at Filtration Media Exposure
 Sampled Date: 02/13/2024
 Received Date: 02/12/2024

Normalization Information:

Date exposure completed: 13-FEB-2024 Calculated N1: 1.00 Field Exposure Time: 1 hours Lab Exposure Time: 1 hours
 Field Media Weight: 625000 mg Lab Media Weight: 609580 mg Calculated NFm: 1.03
 Field Media Volume: 1 L Lab Media Volume: 1.00 L
 Compound Reference Key: SPAC

Testing Parameter	Sample	Control	Result	Normalized Result	Units
Ann Arbor Chemistry Lab					
BASE/NEUTRAL/ACID EPA METHOD 625 modified Scan for Tentatively Identified C					
No Compounds Detected					
Scan Control Complete	TRUE				
Semivolatle Compounds, Base/Neutral/Acid Target 625 modified, Data Workup					
Pyridine	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Nitrosodimethylamine (N-)	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
N-Nitrosomethylethylamine	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
5-Methyl-2-hexanone (MIAK)	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
1-Methoxy-2-propanol acetate	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
2-Heptanone	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Cyclohexanone	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Nitrosodiethylamine (N-)	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Isobutylisobutyrate	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Aniline	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Phenol	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Di(chloroethyl) ether	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
2-Chlorophenol	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
2,3-Benzofuran	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
1,3-Dichlorobenzene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
1,4-Dichlorobenzene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
3-Cyclohexene-1-carbonitrile	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
2-Ethylhexanol	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Benzyl alcohol	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
1,2-Dichlorobenzene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
bis(2-Chloroisopropyl)ether	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
2-Methylphenol (o-Cresol)	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
N-Methylaniline	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Acetophenone	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
N-Nitrosodi-n-propylamine	ND(2)	ND(2)	ND(2)	ND(2)	ug/L



Sample Id: S-0002085626

Testing Parameter	Sample	Control	Result	Normalized Result	Units
Ann Arbor Chemistry Lab (Continued)					
N-Nitrosopyrrolidine	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
3- and 4-Methylphenol (m&p-Cresol)	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Hexachloroethane	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
2-Phenyl-2-propanol	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
N-Nitrosomorpholine	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Nitrobenzene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
2,6-Dimethylphenol	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
N-Vinylpyrrolidinone	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
N-Nitrosopiperidine	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Triethylphosphate	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Isophorone	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
2-Nitrophenol	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
2,4-Dimethylphenol	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
bis(2-Chloroethoxy)methane	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
2,4-Dichlorophenol	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Trichlorobenzene (1,2,4-)	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Naphthalene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
4-Chloroaniline	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
1,1,3,3,-Tetramethyl-2-thiourea	ND(4)	ND(4)	ND(4)	ND(4)	ug/L
Hexachlorobutadiene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Benzothiazole	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
N-Nitrosodi-n-butylamine	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
4-Chloro-3-methylphenol	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
p-tert-Butylphenol	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
2-Ethylhexyl glycidyl ether	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
2,6-Di-t-butyl-4-methylphenol(BHT)	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Methylnaphthalene, 2-	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Cyclododecane	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
2,4,5-Trichlorophenol	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
2,4,6-trichlorophenol	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
1(3H)-Isobenzofuranone	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
2-Chloronaphthalene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
2-Nitroaniline	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
1,1'-(1,3-Phenylene)bis ethanone	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
2,6-Di-tert-butylphenol	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Dimethylphthalate	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
1,1'-(1,4-Phenylene)bis ethanone	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Acenaphthylene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Benzenedimethanol, a,a,a',a'-tetramethyl-1,3-	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
2,6-Dinitrotoluene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
2,4-Dinitrotoluene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Benzenedimethanol, a,a,a',a'-Tetramethyl-1,4-	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
2,4-Di-tert-butylphenol	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Dimethyl terephthalate	ND(2)	ND(2)	ND(2)	ND(2)	ug/L



Sample Id: S-0002085626

Testing Parameter	Sample	Control	Result	Normalized Result	Units
Ann Arbor Chemistry Lab (Continued)					
Acenaphthene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Dibenzofuran	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Ethyl-4-ethoxybenzoate	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
4-Nitrophenol	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Cyclododecanone	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Diethyl Phthalate	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
p-tert-Octylphenol	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Fluorene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
4-Chlorophenylphenylether	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
3-Nitroaniline	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
4-Nitroaniline	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Nitrosodiphenylamine (N-)	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Azobenzene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
4-Bromophenylphenylether	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Hexachlorobenzene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Pentachlorophenol	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Phenanthrene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Anthracene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Diisobutyl phthalate	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Dibutyl phthalate	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Diphenyl sulfone	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Hydroxymethylphenylbenzotriazole	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Fluoranthene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Pyrene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Butyl benzyl phthalate	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Di(2-ethylhexyl)adipate	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
3,3-Dichlorobenzidine	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Benzo(a)anthracene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Di(2-ethylhexyl)phthalate	ND(2)	2	ND(2)	ND(2)	ug/L
Chrysene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Di-n-octylphthalate	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Benzo(b)fluoranthene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Benzo(k)fluoranthene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Benzo(a)Pyrene (PAH)	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Dibenzo(a,h)anthracene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Indeno(1,2,3-cd)pyrene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L
Benzo(g,h,i)perylene	ND(2)	ND(2)	ND(2)	ND(2)	ug/L



Testing Laboratories:

	Id	Address
All work performed at: →	NSF_AA	NSF 789 N. Dixboro Road Ann Arbor MI 48105

References to Testing Procedures:

NSF Reference	Parameter / Test Description
C2023	BASE/NEUTRAL/ACID EPA METHOD 625 modified Scan for Tentatively Identified Compounds (TICs)
C2024	Semivolatile Compounds, Base/Neutral/Acid Target 625 modified, Data Workup

Test descriptions preceded by an asterisk "*" indicate that testing has been performed per NSF requirements but is not within its scope of accreditation.

Unless otherwise indicated, method uncertainties are not applied in any determinations of conformity. Testing utilizes the requested sections of any referenced standards, which may not be the entire standard.

Dates of Laboratory Activity: 13-FEB-2024 to 22-FEB-2024